

LABOR AND MATERIALS

1 Copper ~~Lead~~ Connection 1" \$
 1 Curb Cock Valve 3/4 in. (MARK II LOUISIANA) \$
 T.S. & V. }
 Service box { Short 3 1/2 x 4 1/2 }
 Old returned { Long 4 1/2 x 5 1/2 }
 Buff or Rdway } \$
 52 Ft. 1/2 in. { Copper } Pipe at \$
 { Curb }
 { Curb }
 Nipples in. at \$
 2 Bushings 3/4" to 1/2" in. at \$
 Red'g }
 Inc'g } Coupl'gs. to in. at \$
 2 Union 1/2 in. at MALE FLARE \$
 Meter in. at \$
 1 Lead Joints at BRASS Elbow 1" to 3/4" \$
 Compound Joints at \$
 Maintenance Foreman \$
 Hrs. Water Maint. Man-1 at \$
 Hrs. Water Maint. Man-2 at \$
 Hrs. Garage Foreman at \$
 Hrs. Labor at \$
 Hrs. Compressor at \$
 Compensation Ins. at \$ per C \$
 Trucking \$
 Pav't Patch \$
 Tap Made By L.A. ROSS & CO
 7-26-1972 \$
 O'head \$

This Tap Reduced from 1" Corp Stop To 1/2" Copper

Albert Gift Shop

St. 178
 Pt. To
 Ave. No. 120

GLEN

Name of Owner

Stone Rosenberg

Labor and Mat'l. Report

JUNE 26 1972

No CURB Box. To shut off-
 OPEN MANHOLE IN SIDE WALK
 + USE LONG SHUT OFF
 WRENCH TO SHUT OFF CURB
 BOX INSIDE VAULT ● Curb Box

12" Main

Elev. of Main at tap 5'

Gate at ●

● Gate at

● Curb Box