

AGENDA

County Facilities  
October 28, 2008 - 10:45 am

1.) CALL MEETING TO ORDER..... Ch. John Haskell

2.) OLD BUSINESS

A.) Human Services Building -Update ..... Ch. John Haskell

3.) NEW BUSINESS

A.) Unified Court Maintenance Agreement..... F. Morehouse

B.) Amend Contract - Fire Control Systems, Inc ..... F. Morehouse

C.) Budget Performance Report ..... W. Lamy

D.) HVAC Issues / Information ..... F. Morehouse

4.) PRIVILEGE OF THE FLOOR..... Ch. John Haskell

5.) ADJOURNMENT ..... Ch. John Haskell

## REFERRALS - NOVEMBER 2008

---

---

### COUNTY FACILITIES:

- 1) Health & Human Services Building - Status.
- 2) CPA presented three proposals for additional space to house new voting machines (*renovate old jail, demolish old jail and build new space, add on to the proposed Health & Human Services Building*) Committee to consider proposals. Status. (04.30.08).
- 3) Soil & Water Conservation District Office. Status. (8.17.06)
- 4) Siemens to provide cost justification for standardization of fire, security and intrusion system for County Center. (02.26.08)
- 5) Mr. Morehouse to report costs associated with maintaining electric service to empty DSS Building upon completion of the Health and Human Services Building. (03.26.08)
- 6) Mr. Dusek to research Siemens Technologies Energy Performance Contract to determine what affects changing the temperature set-back times at the Municipal Center would have on projected savings. (06.26.08)

RESOLUTION REQUEST FORM NO. 4

Request for Extending, Rescinding or Amending Existing Contract

DEPARTMENT NAME: BUILDINGS & GROUNDS

DATE: 10/28/08

(a) Purpose of Contract Change: RENEWAL AGREEMENT

(b) Resolution Number, or Numbers if Amended, which Authorized the Original Contract: 487 of 2007

(c) Name of Contractor: STATE OF NEW YORK UNIFIED COURT SYSTEM

(d) Address of Contractor: 65 SOUTH BROWWAY, SUITE 101, SARATOGA, NY 128

(e) Contractor's Contact Person and Telephone Number: \_\_\_\_\_

(f) Commencement Date of Extension: 1 APRIL 2008

(g) Termination Date of Extension: 31 MARCH 2009

(h) Payment Provisions: i) lump sum amount \_\_\_\_\_  
ii) hourly rate amount \_\_\_\_\_  
iii) total amount <sup>LESS THAN</sup> not to exceed 253,536.00  
iv) how will payments be made (i.e. monthly, quarterly, upon completion of the project, etc.)  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(i) Where are the Funds for this Contract? List Budget Code, (with title), Object Code (with title), and Amount OR Capital Project OR Capital Reserve Project Number and Title and Amount: A.1620 . 4  
\_\_\_\_\_  
\_\_\_\_\_

DRAFT

RESOLUTION NO. \_\_\_\_\_ OF 2008

**Resolution introduced by Supervisors Belden, Bentley, Tessier, Stec, Merlino, Haskell, Champagne, Taylor and Goodspeed**

**AUTHORIZING RENEWAL AGREEMENT WITH STATE OF NEW YORK  
UNIFIED COURT SYSTEM FOR COURT CLEANING AND MAINTENANCE  
SERVICES - BUILDINGS & GROUNDS**

RESOLVED, that Warren County continue the agreement (the previous agreement having been authorized by Resolution No. 487 of 2007) with State of New York Unified Court System, 65 South Broadway, Suite 101, Saratoga Springs, New York 12866, for court cleaning and maintenance services within the Warren County Municipal Center, for the renewal period of April 1, 2008 through March 31, 2009, for an amount not less than Two Hundred Fifty-Three Thousand Five Hundred Thirty-Six Dollars (\$253,536), and the Chairman of the Board of Supervisors be, and hereby is, authorized to execute an agreement in the form approved by the County Attorney.

RESOLUTION REQUEST FORM NO. 4

Request for Extending, Rescinding or Amending Existing Contract

DEPARTMENT NAME: BUILDINGS & GROUNDS

DATE: 10/28/08

(a) Purpose of Contract Change: ADDITIONAL SERVICE

(b) Resolution Number, or Numbers if Amended, which Authorized the Original Contract: 284 OF 2008

(c) Name of Contractor: FIRE CONTROL SYSTEMS, INC

(d) Address of Contractor: 104 REYNOLDS ROAD, FORT EDWARD, NY 12828

(e) Contractor's Contact Person and Telephone Number: RICK BALCHER  
518-747-2567

(f) Commencement Date of Extension: 10/16/2008

(g) Termination Date of Extension: 10/15/2009

(h) Payment Provisions: i) lump sum amount \$200/SITE  
ii) hourly rate amount \_\_\_\_\_  
iii) total amount not to exceed \$400  
iv) how will payments be made (i.e. monthly, quarterly, upon completion of the project, etc.)  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(i) Where are the Funds for this Contract? List Budget Code, (with title), Object Code (with title), and Amount **OR** Capital Project **OR** Capital Reserve Project Number and Title and Amount: A.1620.4  
\_\_\_\_\_  
\_\_\_\_\_

Selected Points: \*:room temp  
Selected Panels: \*  
Filter: All Points

Name:Suffix	Address	Description	Value/State	Status	Priority
HEATPMP.01:ROOM TEMP	001 2 03 04	(VESTB 5-101 )	67.75	DEG F -N-	NONE
HEATPMP.02:ROOM TEMP	001 2 02 04	(RM 5-102 TOURISM)	71.25	DEG F -N-	NONE
HEATPMP.03:ROOM TEMP	001 2 01 04	(RM 5-105 TOURISM)	71.00	DEG F -N-	NONE
HEATPMP.04:ROOM TEMP	002 1 09 04	(RM 5-110 a )	74.50	DEG F -N-	NONE
HEATPMP.05:ROOM TEMP	002 1 10 04	(RM 5-110 b )	73.00	DEG F -N-	NONE
HEATPMP.06:ROOM TEMP	002 1 08 04	(Vestibule )	68.00	DEG F -N-	NONE
HEATPMP.07:ROOM TEMP	002 1 07 04	(RM 6-102 )	70.00	DEG F -N-	NONE
HEATPMP.08:ROOM TEMP	002 1 05 04	(RM 6-188 )	71.00	DEG F -N-	NONE
HEATPMP.09:ROOM TEMP	002 1 06 04	(RM 6-103 a )	75.00	DEG F -N-	NONE
HEATPMP.10:ROOM TEMP	002 2 01 04	(RM 6-103 b )	74.75	DEG F *F*	NONE
HEATPMP.100:ROOM TEMP	001 3 08 04	(RM 3-132 )	68.50	DEG F -N-	NONE
HEATPMP.101:ROOM TEMP	001 3 07 04	(RM 3-135 )	69.75	DEG F -N-	NONE
HEATPMP.102:ROOM TEMP	001 3 06 04	(RM 3-137 )	70.00	DEG F -N-	NONE
HEATPMP.103:ROOM TEMP	001 3 03 04	(RM 3-139 )	71.50	DEG F -N-	NONE
HEATPMP.104:ROOM TEMP	001 3 02 04	(3-141 SALLYPORT )	71.75	DEG F -N-	NONE
HEATPMP.105:ROOM TEMP	001 3 01 04	(3-142 MAIL ROOM )	70.50	DEG F -N-	NONE
HEATPMP.106:ROOM TEMP	001 3 04 04	(RM 3-145 )	71.25	DEG F -N-	NONE
HEATPMP.107:ROOM TEMP	001 3 05 04	(RM 3-147 )	70.50	DEG F -N-	NONE
HEATPMP.108:ROOM TEMP	001 3 10 04	(RM 3-150 )	70.00	DEG F -N-	NONE
HEATPMP.109:ROOM TEMP	001 3 11 04	(RM 3-153 )	74.50	DEG F -N-	NONE
HEATPMP.11:ROOM TEMP	002 2 02 04	(RM 6-105 HR )	72.25	DEG F -N-	NONE
HEATPMP.110:ROOM TEMP	001 3 14 04	(RM 3-155 )	71.25	DEG F -N-	NONE
HEATPMP.111:ROOM TEMP	001 3 15 04	(RM 3-157 )	68.00	DEG F -N-	NONE
HEATPMP.112:ROOM TEMP	001 3 13 04	(CORR 3-158 )	70.75	DEG F -N-	NONE
HEATPMP.113:ROOM TEMP	001 3 19 04	(RM 3-163 )	72.50	DEG F -N-	NONE
HEATPMP.114:ROOM TEMP	001 3 23 04	(RM 3-167 )	71.25	DEG F -N-	NONE
HEATPMP.115:ROOM TEMP	001 3 24 04	(RM 3-169 )	72.25	DEG F -N-	NONE
HEATPMP.116:ROOM TEMP	001 3 25 04	(RM 3-170 )	68.75	DEG F -N-	NONE
HEATPMP.117:ROOM TEMP	001 3 26 04	(RM 3-174 )	69.00	DEG F -N-	NONE
HEATPMP.118:ROOM TEMP	001 2 18 04	(RM 3-175 )	71.00	DEG F -N-	NONE
HEATPMP.119:ROOM TEMP	001 2 17 04	(RM 3-128 )	71.25	DEG F -N-	NONE
HEATPMP.12:ROOM TEMP	002 2 03 04	(RM 6-106 )	70.75	DEG F -N-	NONE
HEATPMP.120:ROOM TEMP	001 2 27 04	(CORR 4-108 )	69.75	DEG F -N-	NONE
HEATPMP.121:ROOM TEMP	001 2 26 04	(RM 4-109 )	73.25	DEG F -N-	NONE
HEATPMP.122:ROOM TEMP	001 2 25 04	(CORR 4-119 )	69.25	DEG F -N-	NONE
HEATPMP.123:ROOM TEMP	001 2 24 04	(RM 4-120 )	71.50	DEG F -N-	NONE
HEATPMP.124:ROOM TEMP	001 2 23 04	(RM 4-123 )	73.25	DEG F -N-	NONE
HEATPMP.125:ROOM TEMP	001 2 22 04	(CORR 4-128 )	68.75	DEG F -N-	NONE
HEATPMP.126:ROOM TEMP	001 2 15 04	(RM 4-129 )	70.00	DEG F -N-	NONE
HEATPMP.127:ROOM TEMP	001 2 14 04	(RM 4-134 )	69.25	DEG F -N-	NONE
HEATPMP.128:ROOM TEMP	001 2 16 04	(CORR 4-135 )	70.00	DEG F -N-	NONE
HEATPMP.13:ROOM TEMP	002 3 01 04	(CORR 6-113 c )	69.75	DEG F -N-	NONE
HEATPMP.131:ROOM TEMP	001 2 09 04	(CORR 4-148 )	68.50	DEG F -N-	NONE
HEATPMP.132:ROOM TEMP	001 2 08 04	(CORR 4-162 )	71.50	DEG F -N-	NONE
HEATPMP.134:ROOM TEMP	001 2 12 04	(PENTHOUSE a )	68.75	DEG F -N-	NONE
HEATPMP.135:ROOM TEMP	001 2 13 04	(PENTHOUSE b )	70.25	DEG F -N-	NONE
HEATPMP.136:ROOM TEMP	002 1 13 04	(CORR 5-101 )	70.25	DEG F -N-	NONE
HEATPMP.137:ROOM TEMP	001 2 04 04	(5-104 DA'S OFFIC)	73.00	DEG F -N-	NONE
HEATPMP.138:ROOM TEMP	001 2 05 04	(5-110 DA'S OFFIC)	74.75	DEG F -N-	NONE
HEATPMP.139:ROOM TEMP	001 2 06 04	(5-113 DA'S OFFIC)	76.00	DEG F -N-	NONE
HEATPMP.139A:ROOM TEMP	001 2 07 04	(RM 5-113 a )	73.50	DEG F -N-	NONE
HEATPMP.14:ROOM TEMP	002 3 02 04	(CORR 6-113 d )	71.50	DEG F -N-	NONE
HEATPMP.141:ROOM TEMP	001 1 04 04	(RM 5-123 )	73.00	DEG F -N-	NONE
HEATPMP.142:ROOM TEMP	001 1 03 04	(RM 5-142 )	71.50	DEG F -N-	NONE
HEATPMP.143:ROOM TEMP	001 1 02 04	(RM 5-126 )	74.00	DEG F -N-	NONE
HEATPMP.144:ROOM TEMP	001 1 01 04	(RM 5-127 )	74.50	DEG F -N-	NONE
HEATPMP.145:ROOM TEMP	002 1 12 04	(RM 5-129 )	75.00	DEG F -N-	NONE
HEATPMP.146:ROOM TEMP	002 1 11 04	(RM 5-131 )	75.00	DEG F -N-	NONE
HEATPMP.147:ROOM TEMP	002 1 20 04	(RM 5-201 )	70.50	DEG F -N-	NONE
HEATPMP.148:ROOM TEMP	002 1 21 04	(RM 5-202 )	69.50	DEG F -N-	NONE
HEATPMP.149:ROOM TEMP	002 1 24 04	(RM 5-203 )	70.75	DEG F -N-	NONE
HEATPMP.15:ROOM TEMP	002 2 04 04	(CORR 6-113 a )	70.00	DEG F -N-	NONE
HEATPMP.150:ROOM TEMP	002 1 23 04	(RM 5-204 )	71.75	DEG F -N-	NONE
HEATPMP.151:ROOM TEMP	002 1 19 04	(RM 5-212 )	69.50	DEG F -N-	NONE
HEATPMP.152:ROOM TEMP	002 1 18 04	(RM 5-214 )	71.00	DEG F -N-	NONE
HEATPMP.153:ROOM TEMP	002 1 17 04	(RM 5-216 )	70.50	DEG F -N-	NONE
HEATPMP.154:ROOM TEMP	002 1 15 04	( )	73.75	DEG F -N-	NONE
HEATPMP.155:ROOM TEMP	002 1 16 04	(RM 5-218 )	72.75	DEG F -N-	NONE
HEATPMP.156:ROOM TEMP	002 1 14 04	(RM 5-219 )	69.50	DEG F -N-	NONE
HEATPMP.157:ROOM TEMP	002 1 28 04	(RM 5-221 )	71.75	DEG F -N-	NONE
HEATPMP.158:ROOM TEMP	002 1 27 04	(RM 5-222 )	74.00	DEG F -N-	NONE
HEATPMP.159:ROOM TEMP	002 1 26 04	(RM 5-226 )	74.25	DEG F -N-	NONE
HEATPMP.16:ROOM TEMP	002 2 10 04	(CORR 6-113 b )	70.00	DEG F -N-	NONE

Selected Points: \*:room temp  
 Selected Panels: \*  
 Filter: All Points

Name:Suffix	Address	Description	Value/State	Status	Priority	
HEATPMP.160:ROOM TEMP	002 1 25 04	(RM 5-227 )	72.50	DEG F	-N-	NONE
HEATPMP.17:ROOM TEMP	002 2 12 04	(RM 6-121 )	69.00	DEG F	-N-	NONE
HEATPMP.18:ROOM TEMP	002 2 11 04	(VESTB 6-122 )	71.00	DEG F	-N-	NONE
HEATPMP.19:ROOM TEMP	002 3 30 04	(RM 6-124 b )	71.00	DEG F	-N-	NONE
HEATPMP.20:ROOM TEMP	002 3 29 04	(RM 6-124 a )	71.75	DEG F	-N-	NONE
HEATPMP.200:ROOM TEMP	002 1 03 04	( )	69.00	DEG F	-N-	NONE
HEATPMP.201:ROOM TEMP	002 1 04 04	( )	69.00	DEG F	-N-	NONE
HEATPMP.21:ROOM TEMP	002 3 28 04	(RM 6-125 )	72.50	DEG F	-N-	NONE
HEATPMP.22:ROOM TEMP	002 3 27 04	(RM 6-128 )	70.50	DEG F	-N-	NONE
HEATPMP.23:ROOM TEMP	002 3 25 04	(RM 6-133 )	68.75	DEG F	-N-	NONE
HEATPMP.24:ROOM TEMP	002 3 24 04	(RM 6-134 )	67.25	DEG F	-N-	NONE
HEATPMP.25:ROOM TEMP	002 3 26 04	(RM 6-135 )	68.75	DEG F	-N-	NONE
HEATPMP.26:ROOM TEMP	002 3 23 04	(RM 6-138 )	70.25	DEG F	-N-	NONE
HEATPMP.27:ROOM TEMP	002 3 22 04	(RM 6-139 )	72.25	DEG F	-N-	NONE
HEATPMP.28:ROOM TEMP	002 3 21 04	(RM 6-146 b )	73.50	DEG F	-N-	NONE
HEATPMP.29:ROOM TEMP	002 3 20 04	(RM 6-146 a )	72.75	DEG F	-N-	NONE
HEATPMP.30:ROOM TEMP	002 3 18 04	(RM 6-152 )	70.00	DEG F	-N-	NONE
HEATPMP.31:ROOM TEMP	002 3 17 04	(RM 6-156 )	72.75	DEG F	-N-	NONE
HEATPMP.32:ROOM TEMP	002 3 19 04	(RM 6-158 )	69.75	DEG F	-N-	NONE
HEATPMP.33:ROOM TEMP	002 3 16 04	(RM 6-160 b )	73.75	DEG F	-N-	NONE
HEATPMP.34:ROOM TEMP	002 3 15 04	(RM 6-160 a )	70.75	DEG F	-N-	NONE
HEATPMP.35:ROOM TEMP	002 3 12 04	(RM 6-169 )	68.75	DEG F	-N-	NONE
HEATPMP.36:ROOM TEMP	002 3 09 04	(RM 6-176 )	71.50	DEG F	-N-	NONE
HEATPMP.37:ROOM TEMP	002 3 13 04	(RM 6-177 a )	71.25	DEG F	-N-	NONE
HEATPMP.38:ROOM TEMP	002 3 14 04	(RM 6-177 b )	72.75	DEG F	-N-	NONE
HEATPMP.39:ROOM TEMP	002 3 06 04	(RM 6-178 )	72.25	DEG F	-N-	NONE
HEATPMP.40:ROOM TEMP	002 3 08 04	(RM 6-183 )	71.50	DEG F	-N-	NONE
HEATPMP.41:ROOM TEMP	002 3 04 04	(RM 6-186 )	71.75	DEG F	-N-	NONE
HEATPMP.42:ROOM TEMP	002 3 03 04	(CORR 6-190 a )	73.50	DEG F	-N-	NONE
HEATPMP.43:ROOM TEMP	002 3 10 04	(RM 6-170 )	69.25	DEG F	-N-	NONE
HEATPMP.44:ROOM TEMP	002 3 07 04	(RM 6-190 b )	70.25	DEG F	-N-	NONE
HEATPMP.45:ROOM TEMP	002 3 05 04	(RM 6-191 )	71.00	DEG F	-N-	NONE
HEATPMP.46:ROOM TEMP	002 2 05 04	(RM 6-192 )	71.25	DEG F	-N-	NONE
HEATPMP.47:ROOM TEMP	002 2 06 04	(RM 6-145 )	71.75	DEG F	-N-	NONE
HEATPMP.48:ROOM TEMP	002 2 07 04	(CORR 6-147 )	70.75	DEG F	-N-	NONE
HEATPMP.49:ROOM TEMP	002 2 08 04	(RM 6-200 )	70.50	DEG F	-N-	NONE
HEATPMP.50:ROOM TEMP	002 2 09 04	(RM 6-201 )	73.50	DEG F	-N-	NONE
HEATPMP.51:ROOM TEMP	002 2 14 04	(6-119 CLERK VLT)	70.50	DEG F	-N-	NONE
HEATPMP.52:ROOM TEMP	002 2 15 04	(RM 7-102 )	70.75	DEG F	-N-	NONE
HEATPMP.53:ROOM TEMP	002 2 13 04	(RM 7-103 )	70.25	DEG F	-N-	NONE
HEATPMP.54:ROOM TEMP	002 2 16 04	(RM 7-131 )	71.75	DEG F	-N-	NONE
HEATPMP.55:ROOM TEMP	002 2 22 04	(RM 7-116 )	71.75	DEG F	-N-	NONE
HEATPMP.56:ROOM TEMP	002 2 21 04	(RM 7-119 )	70.75	DEG F	-N-	NONE
HEATPMP.57:ROOM TEMP	002 2 20 04	(RM 7-122 )	70.00	DEG F	-N-	NONE
HEATPMP.58:ROOM TEMP	002 2 19 04	(RM 7-126 )	70.75	DEG F	-N-	NONE
HEATPMP.59:ROOM TEMP	002 2 17 04	(CORR 7-123 )	71.25	DEG F	-N-	NONE
HEATPMP.60:ROOM TEMP	002 2 18 04	(RM 7-129 )	70.50	DEG F	-N-	NONE
HEATPMP.61:ROOM TEMP	002 2 27 04	(RM 7-01 )	70.00	DEG F	-N-	NONE
HEATPMP.62:ROOM TEMP	002 2 26 04	(RM 7-02 )	68.75	DEG F	-N-	NONE
HEATPMP.63:ROOM TEMP	002 2 23 04	(RM 7-03 )	69.50	DEG F	-N-	NONE
HEATPMP.64:ROOM TEMP	002 2 24 04	(RM 7-05 )	71.75	DEG F	*F*	NONE
HEATPMP.65:ROOM TEMP	002 2 25 04	(RM 7-04 a )	71.75	DEG F	-N-	NONE
HEATPMP.66:ROOM TEMP	002 2 28 04	(RM 7-04 b )	70.25	DEG F	-N-	NONE
HEATPMP.67:ROOM TEMP	002 3 11 04	(RM 6-173 )	68.50	DEG F	-N-	NONE
HEATPMP.68:ROOM TEMP	002 1 22 04	(HEATPMP.68 )	68.75	DEG F	-N-	NONE
HEATPMP.69:ROOM TEMP	001 1 20 04	(BSMT CLASSRM )	69.25	DEG F	-N-	NONE
HEATPMP.70:ROOM TEMP	001 1 17 04	(RM 5-101 )	74.25	DEG F	-N-	NONE
HEATPMP.71:ROOM TEMP	001 1 05 04	(CORR 5-126-146 )	69.75	DEG F	-N-	NONE
HEATPMP.72:ROOM TEMP	001 1 06 04	(RM 5-134 KITCHEN)	69.75	DEG F	-N-	NONE
HEATPMP.73:ROOM TEMP	001 1 07 04	(RM 5-120 )	69.25	DEG F	-N-	NONE
HEATPMP.74:ROOM TEMP	001 1 08 04	(RM 5-119 )	71.25	DEG F	-N-	NONE
HEATPMP.75:ROOM TEMP	001 1 09 04	(RM 5-116 )	71.75	DEG F	-N-	NONE
HEATPMP.76:ROOM TEMP	001 1 10 04	(RM 5-115 )	74.25	DEG F	-N-	NONE
HEATPMP.77:ROOM TEMP	001 1 11 04	(RM 5-145 )	70.00	DEG F	-N-	NONE
HEATPMP.78:ROOM TEMP	001 1 12 04	(RM 5-148 )	70.00	DEG F	-N-	NONE
HEATPMP.79:ROOM TEMP	001 1 13 04	(RM 5-111 )	71.50	DEG F	-N-	NONE
HEATPMP.80:ROOM TEMP	001 1 14 04	(RM 5-112 )	73.00	DEG F	-N-	NONE
HEATPMP.81:ROOM TEMP	001 1 15 04	(CORR 5-142a )	70.50	DEG F	-N-	NONE
HEATPMP.82:ROOM TEMP	001 1 16 04	(CORR 5-142b )	74.25	DEG F	-N-	NONE
HEATPMP.83:ROOM TEMP	001 1 19 04	(RM 5-151 )	69.25	DEG F	-N-	NONE
HEATPMP.84:ROOM TEMP	001 1 18 04	(VESTB 5-104 )	72.50	DEG F	-N-	NONE
HEATPMP.85:ROOM TEMP	001 3 27 04	(RM 3-101 )	69.50	DEG F	-N-	NONE
HEATPMP.86:ROOM TEMP	001 2 21 04	(3-102 CTY COURT )	69.25	DEG F	-N-	NONE

Selected Points: \*:room temp  
Selected Panels: \*  
Filter: All Points

Name:Suffix	Address	Description	Value/State	Status	Priority
HEATPMP.87:ROOM TEMP	001 2 19 04	(CORR 3-104 )	72.50	DEG F -N-	NONE
HEATPMP.88:ROOM TEMP	001 3 29 04	(RM 3-106 )	70.75	DEG F -N-	NONE
HEATPMP.89:ROOM TEMP	001 2 20 04	(CORR 3-107 )	69.25	DEG F -N-	NONE
HEATPMP.90:ROOM TEMP	001 3 28 04	(RM 3-105 )	71.75	DEG F -N-	NONE
HEATPMP.91:ROOM TEMP	001 3 30 04	(RM 3-112 )	71.75	DEG F -N-	NONE
HEATPMP.92:ROOM TEMP	001 3 21 04	(RM 3-114 )	76.50	DEG F *F*	NONE
HEATPMP.93:ROOM TEMP	001 3 22 04	(CORR 3-116 )	70.50	DEG F -N-	NONE
HEATPMP.94:ROOM TEMP	001 3 20 04	(RM 3-121 )	69.00	DEG F -N-	NONE
HEATPMP.95:ROOM TEMP	001 3 18 04	(RM 3-122 )	70.00	DEG F -N-	NONE
HEATPMP.96:ROOM TEMP	001 3 17 04	(RM 3-123 )	70.75	DEG F -N-	NONE
HEATPMP.97:ROOM TEMP	001 3 16 04	(RM 3-125 )	71.00	DEG F -N-	NONE
HEATPMP.98:ROOM TEMP	001 3 12 04	(RM 3-126 )	73.50	DEG F -N-	NONE
HEATPMP.99:ROOM TEMP	001 3 09 04	(VESTB 3-128A )	68.75	DEG F -N-	NONE

\*\*\*\*\*  
\*\*\*\*\* End of Report \*\*\*\*\*