

AGENDA

County Facilities
October 27th 2009 - 10:15 am

1.) CALL MEETING TO ORDER.....Ch. Frank Thomas
Approval of Minutes – July 28th 2009

2.) OLD BUSINESS

A.) Human Services Building -Update F. Morehouse

B.) Electrical Switch UpdateF. Morehouse

C.) Generator – DPW / HSB Wm. Lamy

3.) NEW BUSINESS

A.) Municipal Center Heat..... F. Morehouse

B.) Trash Compactor – HSB F. Morehouse

4.) PRIVILEGE OF THE FLOOR..... Ch. Frank Thomas

5.) ADJOURNMENTCh. Frank Thomas

Selection: HEATPMP.01
Match subpoint: <all>

Match Application: <all>

Subpoint #	Name:Suffix	Description	Value	Status	Priority
TEC System Name:HEATPMP.01					
Descriptor: VESTB 5-101					
	HEATPMP.01:ADDRESS		3	-N-	NONE
2	HEATPMP.01:APPLICATION		2072.0	-N-	NONE
3	HEATPMP.01:RETURN DELAY		10.0	MIN -N-	NONE
4	HEATPMP.01:ROOM TEMP	VESTB 5-101	68.5	DEG F -N-	NONE
5	HEATPMP.01:HEAT.COOL	HEAT		-N-	OVRD
6	HEATPMP.01:DAY CLG STPT		80.0	DEG F -N-	NONE
7	HEATPMP.01:DAY HTG STPT		68.0	DEG F -N-	NONE
8	HEATPMP.01:NGT CLG STPT		78.0	DEG F -N-	NONE
9	HEATPMP.01:NGT HTG STPT		63.0	DEG F -N-	NONE
10	HEATPMP.01:DMPR MIN POS		14.8	PCT -N-	NONE
11	HEATPMP.01:RM STPT MIN		55.0	DEG F -N-	NONE
12	HEATPMP.01:RM STPT MAX		90.0	DEG F -N-	NONE
13	HEATPMP.01:RM STPT DIAL		54.5	DEG F -N-	NONE
14	HEATPMP.01:STPT DIAL		NO	-N-	NONE
15	HEATPMP.01:MA TEMP		74.0	DEG F *F*	NONE
***** User-terminated Report *****					
***** End of Report *****					

*This Report Shows
Temp set Points*

Selected Points: *:room temp
Selected Panels: *
Filter: All Points

Name:Suffix	Address	Description	Value/State	Status	Priority
HEATPMP.01:ROOM TEMP	001 2 03 04	(VESTB 5-101)	68.50	DEG F	-N- NONE
HEATPMP.02:ROOM TEMP	001 2 02 04	(RM 5-102 TOURISM)	67.25	DEG F	-N- NONE
HEATPMP.03:ROOM TEMP	001 2 01 04	(RM 5-105 TOURISM)	69.25	DEG F	-N- NONE
HEATPMP.04:ROOM TEMP	002 1 09 04	(RM 5-110 a)	67.50	DEG F	-N- NONE
HEATPMP.05:ROOM TEMP	002 1 10 04	(RM 5-110 b)	67.75	DEG F	-N- NONE
HEATPMP.06:ROOM TEMP	002 1 08 04	(Vestibule)	67.25	DEG F	-N- NONE
HEATPMP.07:ROOM TEMP	002 1 07 04	(RM 6-102)	67.75	DEG F	-N- NONE
HEATPMP.08:ROOM TEMP	002 1 05 04	(RM 6-188)	69.25	DEG F	-N- NONE
HEATPMP.09:ROOM TEMP	002 1 06 04	(RM 6-103 a)	67.75	DEG F	-N- NONE
HEATPMP.10:ROOM TEMP	002 2 01 04	(RM 6-103 b)	68.50	DEG F	-N- NONE
HEATPMP.100:ROOM TEMP	001 3 08 04	(RM 3-132)	67.75	DEG F	-N- NONE
HEATPMP.101:ROOM TEMP	001 3 07 04	(RM 3-135)	68.50	DEG F	-N- NONE
HEATPMP.102:ROOM TEMP	001 3 06 04	(RM 3-137)	68.00	DEG F	-N- NONE
HEATPMP.103:ROOM TEMP	001 3 03 04	(RM 3-139)	68.00	DEG F	-N- NONE
HEATPMP.104:ROOM TEMP	001 3 02 04	(3-141 SALLYPORT)	67.25	DEG F	-N- NONE
HEATPMP.105:ROOM TEMP	001 3 01 04	(3-142 MAIL ROOM)	68.75	DEG F	-N- NONE
HEATPMP.106:ROOM TEMP	001 3 04 04	(RM 3-145)	68.00	DEG F	-N- NONE
HEATPMP.107:ROOM TEMP	001 3 05 04	(RM 3-147)	68.50	DEG F	-N- NONE
HEATPMP.108:ROOM TEMP	001 3 10 04	(RM 3-150)	68.25	DEG F	-N- NONE
HEATPMP.109:ROOM TEMP	001 3 11 04	(RM 3-153)	68.00	DEG F	-N- NONE
HEATPMP.11:ROOM TEMP	002 2 02 04	(RM 6-105 HR)	66.75	DEG F	-N- NONE
HEATPMP.110:ROOM TEMP	001 3 14 04	(RM 3-155)	67.50	DEG F	-N- NONE
HEATPMP.111:ROOM TEMP	001 3 15 04	(RM 3-157)	68.25	DEG F	-N- NONE
HEATPMP.112:ROOM TEMP	001 3 13 04	(CORR 3-158)	68.00	DEG F	-N- NONE
HEATPMP.113:ROOM TEMP	001 3 19 04	(RM 3-163)	67.00	DEG F	-N- NONE
HEATPMP.114:ROOM TEMP	001 3 23 04	(RM 3-167)	67.50	DEG F	-N- NONE
HEATPMP.115:ROOM TEMP	001 3 24 04	(RM 3-169)	67.50	DEG F	-N- NONE
HEATPMP.116:ROOM TEMP	001 3 25 04	(RM 3-170)	67.50	DEG F	-N- NONE
HEATPMP.117:ROOM TEMP	001 3 26 04	(RM 3-174)	68.50	DEG F	-N- NONE
HEATPMP.118:ROOM TEMP	001 2 18 04	(RM 3-175)	67.75	DEG F	-N- NONE
HEATPMP.119:ROOM TEMP	001 2 17 04	(RM 3-128)	68.75	DEG F	-N- NONE
HEATPMP.12:ROOM TEMP	002 2 03 04	(RM 6-106)	67.75	DEG F	-N- NONE
HEATPMP.120:ROOM TEMP	001 2 27 04	(CORR 4-108)	68.25	DEG F	-N- NONE
HEATPMP.121:ROOM TEMP	001 2 26 04	(RM 4-109)	69.00	DEG F	-N- NONE
HEATPMP.122:ROOM TEMP	001 2 25 04	(CORR 4-119)	68.25	DEG F	-N- NONE
HEATPMP.123:ROOM TEMP	001 2 24 04	(RM 4-120)	68.25	DEG F	-N- NONE
HEATPMP.124:ROOM TEMP	001 2 23 04	(RM 4-123)	68.75	DEG F	-N- NONE
HEATPMP.125:ROOM TEMP	001 2 22 04	(CORR 4-128)	68.50	DEG F	-N- NONE
HEATPMP.126:ROOM TEMP	001 2 15 04	(RM 4-129)	69.00	DEG F	-N- NONE
HEATPMP.127:ROOM TEMP	001 2 14 04	(RM 4-134)	67.75	DEG F	-N- NONE
HEATPMP.128:ROOM TEMP	001 2 16 04	(CORR 4-135)	68.25	DEG F	-N- NONE
HEATPMP.13:ROOM TEMP	002 3 01 04	(CORR 6-113 c)	67.75	DEG F	-N- NONE
HEATPMP.131:ROOM TEMP	001 2 09 04	(CORR 4-148)	68.00	DEG F	-N- NONE
HEATPMP.132:ROOM TEMP	001 2 08 04	(CORR 4-162)	69.00	DEG F	-N- NONE
HEATPMP.134:ROOM TEMP	001 2 12 04	(PENTHOUSE a)	67.50	DEG F	-N- NONE
HEATPMP.135:ROOM TEMP	001 2 13 04	(PENTHOUSE b)	69.50	DEG F	-N- NONE
HEATPMP.136:ROOM TEMP	002 1 13 04	(CORR 5-101)	68.50	DEG F	-N- NONE
HEATPMP.137:ROOM TEMP	001 2 04 04	(5-104 DA'S OFFIC)	68.50	DEG F	-N- NONE
HEATPMP.138:ROOM TEMP	001 2 05 04	(5-110 DA'S OFFIC)	71.25	DEG F	-N- NONE
HEATPMP.139:ROOM TEMP	001 2 06 04	(5-113 DA'S OFFIC)	71.50	DEG F	-N- NONE
HEATPMP.139A:ROOM TEMP	001 2 07 04	(RM 5-113 a)	71.75	DEG F	-N- NONE
HEATPMP.14:ROOM TEMP	002 3 02 04	(CORR 6-113 d)	68.50	DEG F	-N- NONE
HEATPMP.141:ROOM TEMP	001 1 04 04	(RM 5-123)	67.75	DEG F	-N- NONE
HEATPMP.142:ROOM TEMP	001 1 03 04	(RM 5-142)	67.75	DEG F	-N- NONE
HEATPMP.143:ROOM TEMP	001 1 02 04	(RM 5-126)	68.75	DEG F	-N- NONE
HEATPMP.144:ROOM TEMP	001 1 01 04	(RM 5-127)	68.50	DEG F	-N- NONE
HEATPMP.145:ROOM TEMP	002 1 12 04	(RM 5-129)	68.00	DEG F	-N- NONE
HEATPMP.146:ROOM TEMP	002 1 11 04	(RM 5-131)	68.50	DEG F	-N- NONE
HEATPMP.147:ROOM TEMP	002 1 20 04	(RM 5-201)	70.25	DEG F	-N- NONE
HEATPMP.148:ROOM TEMP	002 1 21 04	(RM 5-202)	69.50	DEG F	-N- NONE
HEATPMP.149:ROOM TEMP	002 1 24 04	(RM 5-203)	71.75	DEG F	-N- NONE
HEATPMP.15:ROOM TEMP	002 2 04 04	(CORR 6-113 a)	68.25	DEG F	-N- NONE
HEATPMP.150:ROOM TEMP	002 1 23 04	(RM 5-204)	67.50	DEG F	-N- NONE
HEATPMP.151:ROOM TEMP	002 1 19 04	(RM 5-212)	68.00	DEG F	-N- NONE
HEATPMP.152:ROOM TEMP	002 1 18 04	(RM 5-214)	68.50	DEG F	-N- NONE
HEATPMP.153:ROOM TEMP	002 1 17 04	(RM 5-216)	67.75	DEG F	-N- NONE
HEATPMP.154:ROOM TEMP	002 1 15 04	()	68.00	DEG F	-N- NONE
HEATPMP.155:ROOM TEMP	002 1 16 04	(RM 5-218)	67.50	DEG F	-N- NONE
HEATPMP.156:ROOM TEMP	002 1 14 04	(RM 5-219)	68.75	DEG F	-N- NONE
HEATPMP.157:ROOM TEMP	002 1 28 04	(RM 5-221)	68.75	DEG F	-N- NONE
HEATPMP.158:ROOM TEMP	002 1 27 04	(RM 5-222)	68.25	DEG F	-N- NONE
HEATPMP.159:ROOM TEMP	002 1 26 04	(RM 5-226)	69.25	DEG F	-N- NONE
HEATPMP.16:ROOM TEMP	002 2 10 04	(CORR 6-113 b)	68.75	DEG F	-N- NONE

Selected Points: *:room temp
 Selected Panels: *
 Filter: All Points

Name:Suffix	Address	Description	Value/State	Status	Priority
HEATPMP.160:ROOM TEMP	002 1 25 04	(RM 5-227)	69.25	DEG F	-N- NONE
HEATPMP.17:ROOM TEMP	002 2 12 04	(RM 6-121)	67.00	DEG F	-N- NONE
HEATPMP.18:ROOM TEMP	002 2 11 04	(VESTB 6-122)	67.25	DEG F	-N- NONE
HEATPMP.19:ROOM TEMP	002 3 30 04	(RM 6-124 b)	68.00	DEG F	-N- NONE
HEATPMP.20:ROOM TEMP	002 3 29 04	(RM 6-124 a)	68.75	DEG F	-N- NONE
HEATPMP.200:ROOM TEMP	002 1 03 04	()	67.75	DEG F	-N- NONE
HEATPMP.201:ROOM TEMP	002 1 04 04	()	68.25	DEG F	-N- NONE
HEATPMP.21:ROOM TEMP	002 3 28 04	(RM 6-125)	67.75	DEG F	-N- NONE
HEATPMP.22:ROOM TEMP	002 3 27 04	(RM 6-128)	69.25	DEG F	-N- NONE
HEATPMP.23:ROOM TEMP	002 3 25 04	(RM 6-133)	67.50	DEG F	-N- NONE
HEATPMP.24:ROOM TEMP	002 3 24 04	(RM 6-134)	69.50	DEG F	-N- NONE
HEATPMP.25:ROOM TEMP	002 3 26 04	(RM 6-135)	69.25	DEG F	-N- NONE
HEATPMP.26:ROOM TEMP	002 3 23 04	(RM 6-138)	67.25	DEG F	-N- NONE
HEATPMP.27:ROOM TEMP	002 3 22 04	(RM 6-139)	68.00	DEG F	-N- NONE
HEATPMP.28:ROOM TEMP	002 3 21 04	(RM 6-146 b)	68.25	DEG F	-N- NONE
HEATPMP.29:ROOM TEMP	002 3 20 04	(RM 6-146 a)	68.00	DEG F	-N- NONE
HEATPMP.30:ROOM TEMP	002 3 18 04	(RM 6-152)	67.75	DEG F	-N- NONE
HEATPMP.31:ROOM TEMP	002 3 17 04	(RM 6-156)	67.25	DEG F	-N- NONE
HEATPMP.32:ROOM TEMP	002 3 19 04	(RM 6-158)	67.50	DEG F	-N- NONE
HEATPMP.33:ROOM TEMP	002 3 16 04	(RM 6-160 b)	68.25	DEG F	-N- NONE
HEATPMP.34:ROOM TEMP	002 3 15 04	(RM 6-160 a)	69.00	DEG F	-N- NONE
HEATPMP.35:ROOM TEMP	002 3 12 04	(RM 6-169)	67.00	DEG F	-N- NONE
HEATPMP.36:ROOM TEMP	002 3 09 04	(RM 6-176)	72.25	DEG F	-N- NONE
HEATPMP.37:ROOM TEMP	002 3 13 04	(RM 6-177 a)	68.75	DEG F	-N- NONE
HEATPMP.38:ROOM TEMP	002 3 14 04	(RM 6-177 b)	68.25	DEG F	-N- NONE
HEATPMP.39:ROOM TEMP	002 3 06 04	(RM 6-178)	68.00	DEG F	-N- NONE
HEATPMP.40:ROOM TEMP	002 3 08 04	(RM 6-183)	65.75	DEG F	-N- NONE
HEATPMP.41:ROOM TEMP	002 3 04 04	(RM 6-186)	68.25	DEG F	-N- NONE
HEATPMP.42:ROOM TEMP	002 3 03 04	(CORR 6-190 a)	69.00	DEG F	-N- NONE
HEATPMP.43:ROOM TEMP	002 3 10 04	(RM 6-170)	68.75	DEG F	-N- NONE
HEATPMP.44:ROOM TEMP	002 3 07 04	(RM 6-190 b)	69.00	DEG F	-N- NONE
HEATPMP.45:ROOM TEMP	002 3 05 04	(RM 6-191)	68.75	DEG F	-N- NONE
HEATPMP.46:ROOM TEMP	002 2 05 04	(RM 6-192)	68.50	DEG F	-N- NONE
HEATPMP.47:ROOM TEMP	002 2 06 04	(RM 6-145)	68.25	DEG F	-N- NONE
HEATPMP.48:ROOM TEMP	002 2 07 04	(CORR 6-147)	68.25	DEG F	-N- NONE
HEATPMP.49:ROOM TEMP	002 2 08 04	(RM 6-200)	67.75	DEG F	-N- NONE
HEATPMP.50:ROOM TEMP	002 2 09 04	(RM 6-201)	67.50	DEG F	-N- NONE
HEATPMP.51:ROOM TEMP	002 2 14 04	(6-119 CLERK VLT)	69.75	DEG F	-N- NONE
HEATPMP.52:ROOM TEMP	002 2 15 04	(RM 7-102)	68.75	DEG F	-N- NONE
HEATPMP.53:ROOM TEMP	002 2 13 04	(RM 7-103)	68.25	DEG F	-N- NONE
HEATPMP.54:ROOM TEMP	002 2 16 04	(RM 7-131)	70.00	DEG F	-N- NONE
HEATPMP.55:ROOM TEMP	002 2 22 04	(RM 7-116)	67.25	DEG F	-N- NONE
HEATPMP.56:ROOM TEMP	002 2 21 04	(RM 7-119)	69.50	DEG F	-N- NONE
HEATPMP.57:ROOM TEMP	002 2 20 04	(RM 7-122)	67.75	DEG F	-N- NONE
HEATPMP.58:ROOM TEMP	002 2 19 04	(RM 7-126)	67.25	DEG F	-N- NONE
HEATPMP.59:ROOM TEMP	002 2 17 04	(CORR 7-123)	68.00	DEG F	-N- NONE
HEATPMP.60:ROOM TEMP	002 2 18 04	(RM 7-129)	67.50	DEG F	-N- NONE
HEATPMP.61:ROOM TEMP	002 2 27 04	(RM 7-01)	68.25	DEG F	-N- NONE
HEATPMP.62:ROOM TEMP	002 2 26 04	(RM 7-02)	68.25	DEG F	-N- NONE
HEATPMP.63:ROOM TEMP	002 2 23 04	(RM 7-03)	68.00	DEG F	-N- NONE
HEATPMP.64:ROOM TEMP	002 2 24 04	(RM 7-05)	67.75	DEG F	-N- NONE
HEATPMP.65:ROOM TEMP	002 2 25 04	(RM 7-04 a)	69.00	DEG F	-N- NONE
HEATPMP.66:ROOM TEMP	002 2 28 04	(RM 7-04 b)	68.00	DEG F	-N- NONE
HEATPMP.67:ROOM TEMP	002 3 11 04	(RM 6-173)	68.50	DEG F	-N- NONE
HEATPMP.68:ROOM TEMP	002 1 22 04	(HEATPMP.68)	66.00	DEG F	-N- NONE
HEATPMP.69:ROOM TEMP	001 1 20 04	(BSMT CLASSRM)	68.25	DEG F	-N- NONE
HEATPMP.70:ROOM TEMP	001 1 17 04	(RM 5-101)	70.25	DEG F	-N- NONE
HEATPMP.71:ROOM TEMP	001 1 05 04	(CORR 5-126-146)	67.25	DEG F	-N- NONE
HEATPMP.72:ROOM TEMP	001 1 06 04	(RM 5-134 KITCHEN)	67.50	DEG F	-N- NONE
HEATPMP.73:ROOM TEMP	001 1 07 04	(RM 5-120)	68.00	DEG F	-N- NONE
HEATPMP.74:ROOM TEMP	001 1 08 04	(RM 5-119)	67.75	DEG F	-N- NONE
HEATPMP.75:ROOM TEMP	001 1 09 04	(RM 5-116)	67.00	DEG F	-N- NONE
HEATPMP.76:ROOM TEMP	001 1 10 04	(RM 5-115)	68.00	DEG F	-N- NONE
HEATPMP.77:ROOM TEMP	001 1 11 04	(RM 5-145)	68.25	DEG F	-N- NONE
HEATPMP.78:ROOM TEMP	001 1 12 04	(RM 5-148)	67.25	DEG F	-N- NONE
HEATPMP.79:ROOM TEMP	001 1 13 04	(RM 5-111)	67.75	DEG F	-N- NONE
HEATPMP.80:ROOM TEMP	001 1 14 04	(RM 5-112)	67.75	DEG F	-N- NONE
HEATPMP.81:ROOM TEMP	001 1 15 04	(CORR 5-142a)	68.50	DEG F	-N- NONE
HEATPMP.82:ROOM TEMP	001 1 16 04	(CORR 5-142b)	68.50	DEG F	-N- NONE
HEATPMP.83:ROOM TEMP	001 1 19 04	(RM 5-151)	64.00	DEG F	-N- NONE
HEATPMP.84:ROOM TEMP	001 1 18 04	(VESTB 5-104)	67.50	DEG F	-N- NONE
HEATPMP.85:ROOM TEMP	001 3 27 04	(RM 3-101)	67.75	DEG F	-N- NONE
HEATPMP.86:ROOM TEMP	001 2 21 04	(3-102 CTY COURT)	67.75	DEG F	-N- NONE

Selected Points: *:room temp
Selected Panels: *
Filter: All Points

Name:Suffix	Address	Description	Value/State	Status	Priority
HEATPMP.87:ROOM TEMP	001 2 19 04	(CORR 3-104)	68.00	DEG F -N-	NONE
HEATPMP.88:ROOM TEMP	001 3 29 04	(RM 3-106)	67.50	DEG F -N-	NONE
HEATPMP.89:ROOM TEMP	001 2 20 04	(CORR 3-107)	68.25	DEG F -N-	NONE
HEATPMP.90:ROOM TEMP	001 3 28 04	(RM 3-105)	68.50	DEG F -N-	NONE
HEATPMP.91:ROOM TEMP	001 3 30 04	(RM 3-112)	67.75	DEG F -N-	NONE
HEATPMP.92:ROOM TEMP	001 3 21 04	(RM 3-114)	76.50	DEG F *F*	NONE
HEATPMP.93:ROOM TEMP	001 3 22 04	(CORR 3-116)	68.00	DEG F -N-	NONE
HEATPMP.94:ROOM TEMP	001 3 20 04	(RM 3-121)	70.75	DEG F -N-	NONE
HEATPMP.95:ROOM TEMP	001 3 18 04	(RM 3-122)	67.75	DEG F -N-	NONE
HEATPMP.96:ROOM TEMP	001 3 17 04	(RM 3-123)	67.00	DEG F -N-	NONE
HEATPMP.97:ROOM TEMP	001 3 16 04	(RM 3-125)	67.25	DEG F -N-	NONE
HEATPMP.98:ROOM TEMP	001 3 12 04	(RM 3-126)	67.75	DEG F -N-	NONE
HEATPMP.99:ROOM TEMP	001 3 09 04	(VESTB 3-128A)	67.75	DEG F -N-	NONE

***** End of Report *****